

TUBOS SCHEDULE - RR (NBR 5590)

DENOMINAÇÃO			ESPESS. DE PAREDE mm	PESO KG/M	DENOM.	SCHEDULE Nº
NOMINAL POL.	EXTERNO mm	INTERNO mm				
1/4"	13,72	9,24	2,24	0,63	STD	40
		7,68	3,02	0,80	XS	80
3/8"	17,15	12,53	2,31	0,85	STD	40
		10,75	3,20	1,10	XS	80
1/2"	21,34	15,80	2,77	1,26	STD	40
		14,16	3,73	1,62	XS	80
3/4"	26,67	20,93	2,87	1,68	STD	40
		18,85	3,91	2,19	XS	80
1"	33,40	26,64	3,38	2,50	STD	40
		24,30	4,55	3,23	XS	80
1.1/4"	42,60	35,04	3,56	3,38	STD	40
		32,46	4,85	4,46	XS	80
1.1/2"	48,26	40,90	3,68	4,05	STD	40
		38,10	5,08	5,40	XS	80
2"	60,32	52,50	3,91	5,43	STD	40
		49,24	5,54	7,47	XS	80
2.1/2"	73,03	62,71	5,16	8,62	STD	40
		59,01	7,01	11,40	XS	80
3"	88,90	77,92	5,49	11,28	STD	40
		73,66	7,62	15,25	XS	80
3.1/2"	101,60	90,12	5,74	13,56	STD	40
		85,44	8,08	18,60	XS	80
4"	114,30	102,26	6,02	16,06	STD	40
		97,18	8,56	22,29	XS	80
5"	141,30	128,30	6,55	21,75	STD	40
		122,26	9,52	30,92	XS	80
6"	168,30	154,08	7,11	28,23	STD	40
		146,36	10,97	42,51	XS	80
8"	219,10	202,74	8,18	42,49	STD	40
		199,70	12,70	65,95	XS	80

OBS: Eventuais diferenças de cálculo no peso deve-se a tolerância da espessura de $\pm 10\%$